

# **EIGHTEENTH QUARTERLY REPORT**

**(PERIOD: JULY 1, 2020 TO SEPTEMBER 30, 2020)**

**PARTIAL CONSENT DECREE CASE NO. 4:16-CV-00018**  
**CITY OF GREENVILLE, MS**

**SUBMITTED TO:**

U.S. Environmental Protection Agency, Region 4  
Clean Water Enforcement Branch  
61 Forsythe Street, S.W.  
Atlanta, GA 30303-8960



**October 23, 2020**


## CERTIFICATION

### **18<sup>th</sup> Quarterly Report**

Partial Consent Decree

City of Greenville

I certify under penalty of law that this document and all its attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.



Errick D. Simmons, Mayor

10-19-20

Date

### **CC Addresses:**

Dennis Sayre, EPA Region IV; sayre.dennis@epa.gov

Brad Ammons, EPA Region IV; ammons.brad@epa.gov

Diane Schober, MDEQ; dschober@mdeq.ms.gov

Gretchen Zmitrovich, MDEQ; gzmitrovich@mdeq.ms.gov

Bailey Long, MDEQ; blong@mdeq.ms.gov

William Burle, Jr., W.L. Burle, P.A.; wlbjr@wlburl.com

Mayor Errick Simmons; edsimmons@greenvillems.org

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
	7/1/2020		SSO	1148 Highland Plantation Road								670 Sewer		Yes	20	10000	No	Focemain Break	2 26		84
	9/8/2020		SSO	1840 Palmyra								670 Sewer		Yes	1.75	200	No	Bypass Pump		1 27	42
	9/18/2020		SSO	1148 Highland Plantation Road								670 Sewer		Yes	unknown	2500	No	Focemain Break	2 26		84
62572	7/8/2020	Open	Municipal Court	302 Main Street	378.1522			sewage tissue in parking lot- stoppage			Bridgett Winters	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		3 4B	7
62609	7/13/2020	Open	Shree Smith	548 Gaylo	662-822-5683		rear of property	sewer issue with the pump, yard is saturated with water	sewer maintenance / pump		Bridgette Adley	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		1 27	42
62772	7/31/2020	Open	Lillian hawkins	429 4th	702.3860		near the ditch - front yard	sewage or water bubbling up with a smell			Bridgett Winters	670 Sewer	Jeff Appleton	yes	unknown	unknown	unknown	unknown		3 16	54
62802	8/3/2020	Open	James Williams	331 South Hinds Street	662-347-1131			"Sewage Leak" is located on the north side of the citizen's home. A traffic cone is placed on the location of the leak			Kyla Rice	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		3 4A	7
62847	8/6/2020	Closed	Shirley cork	915 South Theobald	6623472735		Next to this address	The apartment complex next to this address is having sewage issues; sewage is seeping from the apartments to her yard; Come out ASAP	Cleared // R Sawyer	8/7/2020	Lauren Gales	670 Sewer	Jeff Appleton		unknown	unknown	unknown	unknown		2 5	14
62906	8/12/2020	Closed	Allen and Griffin	204 Highway 1 South	662-332-0592			Sewage is backing up in the hallway drains and in the kennel area outside	Cleared // R Sawyer	8/14/2020	Kyla Rice	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		3 16	54
63344	9/4/2020	Closed	McGarh	339 South Theobald	662-347-2453		apartment (rear)	sewage running in the backyard of complex	Cleared // R Sawyer	9/9/2020	Bridgette Adley	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		3 4A	7
63705	9/25/2020	Closed	Earnest Ellis	1738 Spruce St.	6623368222			Water is stopped up in the backyard; water	Cleared / R Sawyer	9/25/2020	Lauren Gales	670 Sewer	Jeff Appleton	Yes	unknown	unknown	unknown	unknown		1 19B	28
62490	7/1/2020	Closed	Ann Thomas	460 Muscadine St	6623474277			sewer issue	Main down, problem on homeowner // Sawyer	7/2/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3A	55
62491	7/1/2020	Closed	R. WASHINGTON	2358 Whipporwill Dr				sewer issue	Cleared // Sawyer	7/2/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 28A	53
62496	7/1/2020	Closed	citizen	418 Maples	901-282-4006			citizen states toilet is barely flushing	Cleared // Sawyer	7/2/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 4A	7
62500	7/1/2020	Closed	Simpson's A/C	209 Dallas	662-332-2354			citizen states toilet is barely flushing	No cleanout, main down // Sawyer	7/2/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 12	36
62505	7/1/2020	Closed	Jerry Kersh	3537 Forrest	662-390-3719			citizen states toilet is barely flushing	Sewer failure here// Sawyer	7/2/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 29	25
62513	7/2/2020	Open	Clarence Smith	235 Central St	6625806065			sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						3 4A	7
62516	7/2/2020	Open	R. WASHINGTON	Fire Station #5				sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						1	
62520	7/2/2020	Closed	Willie Wheeler	2561 Bobolink Place	662-336-0344			citizen states toilet is barely flushing	Cleared//Sawyer	7/8/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
62521	7/2/2020	Closed	citizen	3561 Forrest				citizen states toilet is barely flushing	Sewer failure/arked//Sawyer	7/6/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 29	25
62523	7/2/2020	Closed	Ketoric Sutton	2238 Timber Cove	662-537-6061		clean out in the front	citizen states toilet is barely flushing	Cleared // Sawyer	7/6/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
62524	7/2/2020	Closed	Sherdon	2561 Boblink	347.8848			sewage stoppage- clean out in front yard	Cleared // Sawyer	7/6/2020	Bridgett Winters	670 Sewer	Ronnie	No						2 28A	53
62525	7/6/2020	Closed	Phyliss Austin	437 7th	822-1500			sewage stoppage occurred once the Atmos put a line down	Cleared//Sawyer	7/7/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						1 18	28
62526	7/6/2020	Closed	Freddie Grayson	359 E Starling	580.2569			sewage stoppage on going issue	Cleared // Sawyer	7/7/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						1 3C	55
62529	7/6/2020	Closed	Wade Dotson	1111 Boyd St	6623941806			sewer issue	Sewer failure//Sawyer	7/8/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 7	16
62530	7/6/2020	Closed	Joan Hearn	514 Pleasant	822.0205			3rd week calling- plumber wants city cap the			Bridgett Winters	670 Sewer	Ronnie	No						3 17	9
62531	7/6/2020	Closed	Green	3545 Forrest drive	601.955.0480		other homes are effected	sewage stoppage - three weeks	Sewer failure here // Sawyer	7/7/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						2 29	25
62532	7/6/2020	Closed	citizen	1811 May Street	662-809-3618			citizen can not flush toilets.	Cleared // Sawyer	7/7/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 18	66
62533	7/6/2020	Closed	Keith	1220 Celeste	662-820-2620			citizen states toilet is barely flushing	Clear//Sawyer	7/8/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 23	34
62538	7/6/2020	Closed	R. WASHINGTON	642 W Chatham Dr				sewer issue	No cleanout, main down // Sawyer	7/7/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 2	5
62546	7/7/2020	Open	Atlee Blackmon	1066 Baskin Drive	662-820-0172			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 21A	29
62553	7/7/2020	Closed	citizen	801 Bay Street	62-537-8802			citizen states toilet is barely flushing	Cleared//Sawyer		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 32B	20
62556	7/7/2020	Closed	Chiticia Burden	1629 W Pear Ln	6626955590			sewer issue	Cleared//Sawyer	7/8/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 24	32
62568	7/8/2020	Open	citizen	Idelwild	662-822-0307		corner of Idelwild &	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 27	42
62569	7/8/2020	Open	citizen	Idelwild	662-822-0307		corner of Idelwild & Susan	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 27	42
62571	7/8/2020	Open	citizen	851 Hart	662-820-1361			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer		No						3 19A	28
62573	7/8/2020	Closed	C Allen / Estella Addison	1029 Sisson Drive	394.1985		you didn't come back and fill the hole	sink hole near mailbox- fill up or make repair	No sewer issue here//Sawyer	7/9/2020	Bridgett Winters			No						2 1	1A
62575	7/8/2020	Closed	Betty Weatherspoon	727 Phelps St.	7082052769			sewer issue	Cleared // Sawyer	7/10/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 8	17
62580	7/9/2020	Closed	Scott Tsantz	629 Paul Cove	6624301009			sewer issue	Cleared //Sawyer	7/10/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 27	71
62581	7/9/2020	Closed	Sherman Harris	2434 S Paducah	820.3099			sewage stopped up at street	Cleared // Sawyer	7/10/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						1 31B	23
62597	7/10/2020	Open	Cleveland Green	3545 Forest Dr	6019550480			sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						2 29	25
62599	7/13/2020	Closed	R. WASHINGTON	1066 Baskin Dr				sewer issue	Cleared // Sawyer	7/14/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 21A	29
62606	7/13/2020	Open	David Potin	466 Idelwild	347.1186			sewer line broken, front yard near side walk			Bridgett Winters	670 Sewer	Jermaine Thornton	No						1 27	42
62610	7/13/2020	Closed	Antonia Lucius	2358 Whhipporwill	6623474640			sewer issue	Cleared // Sawyer	7/14/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 28A	53
62621	7/14/2020	Open	Carolyn Hayes	1067 Duncan Drive	394.0579		sewage stoppage - open				Bridgett Winters	670 Sewer	Jeff Appleton	No						2 1	1A
62622	7/14/2020	Closed	Charles Williams	619 W. McCorkel	662-616-6231			citizen states toilet is barely flushing	Cleared / R Sawyer	7/14/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	28
62624	7/14/2020	Closed	R. WASHINGTON	2522 Sarullo Cir				sewer issue	Main down, problem on property owner/ Sawyer	7/14/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 20	27
62630	7/14/2020	Open	citizen	1419 Kirkland	662-344-3733			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						3 20	28
62637	7/15/2020	Open	Citizen	221 N Colorado St				sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						1 18	28
62640	7/15/2020	Closed	citizen	3537 Forest	662-390-3719			citizen states toilet is barely flushing	Sewer failure @ Woodlawn Dr.//R Sawyer	7/16/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 29	25
62643	7/15/2020	Open	Willie Campbell	712 E Starling St	6623327510			sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						2 15	10

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
62647	7/16/2020	Closed	R. WASHINGTON	515 McAllister				sewer issue	City cleanout & Main line down/problem on property owner// R Sawyer	7/17/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 13	10
62651	7/16/2020	Closed	J. Thornton c/o Michael Sanders	1807 Palmyra				citizen states toilet is barely flushing	City pump needs service// R Sawyer	7/17/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 27	71
62658	7/17/2020	Closed	R. WASHINGTON	1725 Dahlia St				sewer issue	Cleared // R Sawyer	7/20/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 12	35
62662	7/17/2020	Closed	R. WASHINGTON	627 Wildwood St				sewer issue	Sewer failure on 615 Wildwood //R Sawyer	7/20/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 27	71
62665	7/20/2020	Closed	Apartment/Broadway Estate	1036 S Broadway	820.9920			stoppage- sewer lines are filled with water	Main line down // R Sawyer	7/20/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						2 5	14
62678	7/22/2020	Closed	Hughes Plumbing	1530 Les Lane	822.3691			stoppage on city line	Main down, problem on homeowner // R Sawyer	7/23/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						2 21A	29
62682	7/22/2020	Closed	Ruby Jones	611 E McCorkle Cir	6623354607			sewer issue	Main down, problem on Property Owner // R Sawyer	7/23/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 20	28
62683	7/23/2020	Open	David Potin	466 Idlewild	662.347.1186			collpased sewer line, has informed Jermaine about this- open hole			Bridgett Winters	670 Sewer	Jermaine Thornton	No						1 27	42
62685	7/23/2020	Closed	Antwon Jones	328 Ohio	901.430.6713			sewage stoppage on city side according to plumbers	CITY main down, no cleanout // R Sawyer	7/24/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						1 30	56
62692	7/23/2020	Closed	Vickie Jones	328 Ohio Street	901-246-6766			citizen states toilet is barely flushing	CITY main down, no cleanout // R Sawyer	7/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
62696	7/23/2020	Closed	Shurden Plumbers	312 Saint Anthony	662-820-1653			citizen states toilet is barely flushing	Cleared // R Sawyer	7/27/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 10	38
62698	7/24/2020	Closed	Freddie Greyson	359 E Starling St	6623470206			sewer issue	Cleared // R Sawyer	7/27/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3C	55
62699	7/24/2020	Closed	Bowie	651 Rosedale	678.594.4284			sewage stoppage	Main down / problem on property owner // R sawyer	7/27/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						2 23	34
62703	7/24/2020	Closed	Charles Shoffner	651 Rosedale	662-378-2305			citizen states toilet is barely flushing	Main down, problem on property owner	7/27/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 23	34
62704	7/24/2020	Closed	J. Thornton	2602 North Broadway Ext				citizen states toilet is barely flushing	Dig-out CITY// R Sawyer	7/27/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 1	1
62713	7/27/2020	Closed	#6	1181 Groom St.				sewer issue	Cleared / R Sawyer	7/27/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 23	34
62714	7/27/2020	Closed	Charles Williams	819 E McCorkle Cir	6626166231			sewer issue	Cleared / R Sawyer	7/27/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 20	28
62715	7/27/2020	Closed	Pearlie Chase	414 McAllister	662-580-2862			citizen states toilet is barely flushing	Cleared // R Sawyer	7/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 3C	55
62719	7/27/2020	Closed	citizen	815 Guerdon Rad	662-820-3309		Bayou Estates	citizen states toilet is barely flushing	Dig-out CITY // R Sawyer	7/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 26	45
62725	7/27/2020	Closed	Tara Haymond	1102 Groome	662-390-7093			citizen states toilet is barely flushing	Cleared // R Sawyer	7/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 21A	29
62726	7/27/2020	Closed	Michael Prewitt	116 Goldstein	662-820-7067			citizen states toilet is barely flushing	Cleared // R Sawyer	7/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 13	10
62728	7/27/2020	Closed	Blac Williams	3554 Sherwood drive	662-334-6523			citizen states toilet is barely flushing	Cleared // R Sawyer	7/29/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 29	25
62733	7/28/2020	Closed	Ricky Dava	1202 Hwy 82 East	662-347-8352			citizen states toilet is barely flushing	Cleared // R Sawyer	7/29/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 16	54
62734	7/28/2020	Closed	George Sherdon	1297 Waxhaw	390.7387		corne Groome	sewer line caved in - collapsed line	Sewer failure here // R Sawyer	7/29/2020	Bridgett Winters	670 Sewer	Jermaine Thornton	No						1 21A	29
62740	7/28/2020	Closed	R. WASHINGTON	479 Poplar St.				sewer issue	No sewer issue/ hole in street // R Sawyer	7/29/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3B	55
62744	7/28/2020	Closed	J. Thornton	328 Ohio				citizen states toilet is barely flushing	Main down, problem on property owner, she has been notified // R Sawyer	7/30/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
62748	7/29/2020	Closed	KB @ DAYS INN	2701 HWY 82 EAST	704 644-9339			sewage issue on first floor	System is up // R Sawyer	7/30/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						1 20	58
62750	7/29/2020	Closed	James Bush	959 Legion Dr.	662-336-3745			citizen states toilet is barely flushing	Main down, no CITY cleanout,notified // R Sawyer	7/30/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 32B	20
62751	7/29/2020	Closed	citizen	328 Ohio Street	901-430-6713			citizen states toilet is barely flushing	Main down, problem on property owner,	7/30/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
62764	7/30/2020	Closed	Grace K	2900 Treatment Plant Road	347.8424	William McLamar- is the plumbing		plumber is there- sewage stopped up	Cleared // R Sawyer	7/31/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						2 26	104
62768	7/31/2020	Closed	citizen	1496 West Ollie Circle	662-390-6642			citizen states toilet is barely flushing	Cleared // R Sawyer	7/31/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 23	34
62777	7/31/2020	Closed	Eric Smart	432 South Eureka	662-822-3582			citizen states toilet is barely flushing	Cleared // R Sawyer	8/5/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 14	10
62778	7/31/2020	Open	Alex Singletary	714 East Moore	662-344-2425			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 15	10
62779	7/31/2020	Closed	R. WASHINGTON	2602 N. Broadway Ext				sewer issue	Dig-out on City // R Sawyer	8/4/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 1	1
62783	7/31/2020	Closed	Blanch Pennington	3554 Sherwood Dr.	6623346523			sewer issue	Cleared // R Sawyer	8/4/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 29	25
62788	8/3/2020	Closed	Mike Moore	1811 May Street	662-537-4083			citizen states toilet is barely flushing	Main & cleanout down, problem inside home //		Bridgette Adley	670 Sewer	Ronnie	No						1 18	66
62797	8/3/2020	Closed	Minnie Mccarter	726 South Delesseps apt A	6629314717			sewage is backing up; needs to be pumped out	Cleared // R SAWyer	8/5/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						2 7	16
62809	8/4/2020	Closed	Cassette Jones	1646 East David Circle	662-931-6600			citizen states toilet is barely flushing	Cleared // R Sawyer		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 24	32
62810	8/4/2020	Closed	Demetira Gamill	1414 Sandy Ave.	662-335-9891			citizen states toilet is barely flushing	Cleared // R Sawyer	8/6/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 9B	40
62812	8/4/2020	Closed	Jessica Davis	948 Arnold Avenue	662-822-8581			Possible sewage blockage	CITY side ok, problem on Property Owner,	8/6/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 13	10
62821	8/4/2020	Closed	Boone Funeral Home	905 Main Street	662-335-7111			citizen states toilet is barely flushing	Cleared / R Sawyer	8/6/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 3C	55
62827	8/5/2020	Closed	Janet Jackson	549 Solomon	662-931-4054			citizen states toilet is barely flushing	Cleared //R Sawyer	8/6/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 18	28
62832	8/5/2020	Open	R. WASHINGTON	334 Wetherbee St				sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						3 9B	40
62834	8/5/2020	Open	Bessie Yates	411 West Ohea Street	601-454-5906			Sewage problem. Blow out sewer line	Sewage is backing up into the bathtub		Kyla Rice	670 Sewer	Jeff Appleton	No						1 3D	55
62836	8/5/2020	Closed	Animal Clinic	1902 Highway 1 South	662-820-7697			Sewage problem	Cleared // R Sawyer	8/7/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 28A	53
62837	8/5/2020	Closed	Johnmarr Jackson	2238 Timber Cove	662-347-3239			citizen states toilet is barely flushing	Cleared // R Sawyer	8/7/2020	Bridgette Adley	670 Sewer	Bridgette Adley	No						2 28A	53
62843	8/6/2020	Closed	Dr. Richardson	302 Arnold Ave	6628223691			Drain stopped up on the city's side	cleared // R Sawyer	8/7/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 3C	55
62852	8/7/2020	Closed	Terry Gales	514 Johnson	662-379-0412			citizen states toilet is barely flushing	Cleared // R Sawyer	8/10/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 4A	7
62859	8/10/2020	Closed	Chesterene Foster	1052 Goodrich	662-820-9849		sewer pump not working	citizen states toilet is barely flushing	Dig-out CITY // R Sawyer	8/10/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 7	16
62860	8/10/2020	Closed	Chris Guest	330 Nancy	6628220887			Sewer line is backing up into the apartment	Dig-out CITY.. R Sawyer	8/10/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 9A	40
62867	8/10/2020	Open	Allen and Griffen	204 Highway 1 South	6623350592			Sewer is backed up; plumber said it is on the city's side			Lauren Gales	670 Sewer	Jeff Appleton	No						3 16	54

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
62876	8/10/2020	Closed	citizen	1203 Kirk Circle	662-347-3359			citizen states toilet is barely flushing	Drain line problem, cleanout ok // R Sawyer	8/12/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 25	11
62877	8/10/2020	Closed	Hughes Plumbers	300 Washington Ave.	6628223691			sewer issue at hospital	Opened line, but a dig-out here // R Sawyer	8/11/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3D	55
62881	8/11/2020	Closed	Chris Guest	330 Nancy Street	662-822-0887		plumber states sewer line has collapsed	citizen states toilet is barely flushing	Dig-out CITY // R Sawyer	8/12/2020	Bridgette Adley	670 Sewer	Bridgette Adley	No						1 9A	40
62886	8/11/2020	Closed	Tommie Sanders	1349 Causey	662-820-8177			reporting manhole sinking in, broken concrete	Reported to R Washington // R Sawyer	8/12/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 22A	34
62896	8/12/2020	Closed	Shirley Dukes	554 N Abraham St.	6625227469			Sewage is backing up into house	Cleared / R Sawyer	8/13/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 18	28
62898	8/12/2020	Open	Vera Subelett	330 Nancy St.	6626329008			Toilet is backed up; plumber said it is on the city			Lauren Gales	670 Sewer	Jeff Appleton	No						1 9A	40
62901	8/12/2020	Closed	Shurden plumbers	2680 Airdale Dr.	6629314489			sewer issue	Cleared / R Sawyer	8/13/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 1	1
62916	8/13/2020	Closed	custodian	OBannon High School			school	citizen states toilet is barely flushing	System pulling down // R Sawyer	8/14/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 28A	26
62917	8/13/2020	Closed	Taurus McElvaine	1461 Highland St.	6629312141			Water is backing up in the yard; may be on the city	Storm sewer, rain // R Sawyer	8/14/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 9B	40
62918	8/13/2020	Closed	Thomas Knight	1516 South Delesseps St.	6623475133			Sewer is stopped up; cannot flush the toilet	System pulling down // R Sawyer	8/14/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 8	17
62919	8/13/2020	Open	David Potin	466 Idlewild	662-347-1186		front yard sinking deeper	collapsed sewer line complaint	update work status on this sewer issue with the citizen		Bridgette Adley	670 Sewer	Jermaine Thornton	No						1 27	42
62922	8/13/2020	Open	R. W Ashington	1516 S Delesseps St				sewer issue			M. Kearney	670 Sewer	Jeff Appleton	No						1 8	17
62924	8/13/2020	Closed	Williams	2046 Hwy 82 E	6628223691			drain blocked/ car wash	Drain blocked, private property, can wash // R Sawyer	8/14/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 19B	28
62934	8/14/2020	Closed	Charlie Gains	1319 Allsaint Circle	662-580-2901			Sewage is backing up in the bathtubs	CITY side is clear, problem on property owner // R Sawyer	8/14/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 22A	34
62944	8/17/2020	Closed	Keiton Sutton	2238 Timber Cove	6625276061			sewer issue	Line cleared // R Sawyer	8/18/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 28A	53
62950	8/17/2020	Open	Tom Rush- Roses	3001 Hwy 82 East	919-812-4878			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 29A	52
62953	8/17/2020	Closed	Roses and Tractor Supply	3001 Highway 82	6623479051			Toilets are stopped up; sewer is backed up; Emergency	City side down, problem on property owner // R Sawyer	8/18/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 29A	52
62954	8/17/2020	Closed	Vera Sublett	330 Nancy St.	6626329008		Duplex	Sewer issues on the city; toilets are not flushing	Line repaired by CITY // R Sawyer	8/18/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 9A	40
62959	8/17/2020	Open	citizen	234 South Paducah	662-820-3099			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 31B	23
62960	8/17/2020	Open	citizen	2434 South Paducah	662-820-3099			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 31B	23
62962	8/17/2020	Closed	Ellen Harris	913 Tampa Drive	240-472-1282		lake side/ new development	sewage seepage/ smell of raw sewage	No issue found // R Sawyer	8/20/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 26	84
62965	8/17/2020	Closed	Citizen	1181 Groom St.				sewer issue	Main down, problem on property owner // R Sawyer	8/18/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 23	34
62971	8/17/2020	Closed	Carolyn Dillard	1059 Duncan Drive	662-344-3930				Cleared // R Sawyer	8/19/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 1	1
62992	8/18/2020	Closed	citizen	478 Plum	662-820-4075			citizen states toilet is barely flushing	Main line down, problem on property owner // R Sawyer	8/19/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 3E	6
62994	8/18/2020	Closed	R. W Ashington	861 North Theobald St				sewer issue	System up // R Sawyer	8/19/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 2	5
62995	8/18/2020	Closed	Kevin (Contractor)	834 North Theobald	3185480037			sewer line is backed up; they are at the end of the line	System up // R Sawyer	8/19/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 2	5
62996	8/18/2020	Closed	Phyllis Austin	437 7th St.	6628221500			sewage problems; water is backing up into home	Cleared // R Sawyer	8/19/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 18	28
62997	8/18/2020	Closed	Title Loan	2621 Hwy 82 East				citizen states toilet is barely flushing	Cleared // R Sawyer	8/19/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	58
62998	8/18/2020	Closed	Phyllis Austin	437 7th Street	662-822-1500			citizen states toilet is barely flushing	Cleared // R Sawyer	8/19/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 18	28
63019	8/19/2020	Closed	Thomas Jackson	670 East McCorkel	662347-1817		clean out at the front	citizen states toilet is barely flushing	Cleared // R Sawyer	8/20/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	28
63022	8/19/2020	Closed	citizen	720 South California	662-820-1438			citizen states toilet is barely flushing	Cleared // R Sawyer	8/20/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 21B	29
63046	8/19/2020	Closed	Patricia Yates	411 West Ohea	662-335-3030			citizen states toilet is barely flushing	Cleared // R Sawyer	8/21/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 3D	55
63054	8/20/2020	Closed	Malcom Jackson	400 Block of South Broadway	662-822-8342			Please clean out sewer line at apartment complex	Cleared // R Sawyer	8/21/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 4	7
63061	8/20/2020	Closed	Jennifer Jamerson	1033 West Alexander St.	2818488985			Sewage is backing up into home	Dig-out on CITY // R Sawyer	8/21/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 3C	55
63063	8/20/2020	Closed	L. Shurden plumbers	751 Dallriva Dr.	6623478848			sewer issue	Cleared // R Sawyer	8/21/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 8	17
63096	8/21/2020	Closed	citizen	330 Mathis ( Nancy St.)	662-632-9008			citizen states toilet is barely flushing	Needs repair in CITY // R Sawyer // (This is 330 Nancy St.)	8/21/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9B	40
63098	8/21/2020	Open	Jennifer Jamerson	1033 West Alexander Street	218-848-8385				Sewage is backing up. Please clean out sewer line.		Kyla Rice	670 Sewer	Jeff Appleton	No						1 3C	55
63102	8/21/2020	Closed	citizen	2434 South Padueha	662-820-3099			citizen states toilet is barely flushing	Cleared // R Sawyer	8/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 31B	23
63109	8/24/2020	Closed	Lance Rutledge	621 Rosedale St.	6628203151			sewer issue, no cleanout	No cleanout, main line down //R Sawyer	8/25/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 25	11 & 12
63110	8/24/2020	Closed	Teva White	525 N Delta St.	6628221069			sewer issue	Dig-out on CITY, marked / R Sawyer	8/25/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 18	28
63113	8/24/2020	Closed	Sheldon Plumbing	333 North Shelby	662-390-7387			citizen states toilet is barely flushing	Cleared // R Sawyer	8/25/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 3D	55
63125	8/24/2020	Open	Citizen	330 Nancy St.	6626329008			sewer issue still			M. Kearney	670 Sewer	Jeff Appleton	No						1 9A	40
63127	8/25/2020	Closed	Casandra Gilmore	742 Jefferson Dr.	6624006997			sewer issue	Cleared // R Sawyer	8/26/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 19A	28
63135	8/25/2020	Closed	Frank Stanford	895 Guerdon Rd.	6623941910			sewer issue	repaired 4' sewer service line R.King		M. Kearney	670 Sewer	Jeff Appleton	No						2 26	45
63141	8/25/2020	Closed	Alex Taylor	659 East McCorkle	662-378-1691			citizen states toilet is barely flushing	Line clear, NO sewer problem / R Sawyer	8/26/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	28
63153	8/26/2020	Open	Freddie Todd	1008 Patton Dr.	6628221940			Toilet wont flush; sewer issues			Lauren Gales	670 Sewer	Jeff Appleton	No						1 32B	20
63165	8/26/2020	Closed	Arce! Townsend	705 East Alexander	662-580-6227		clean-out outside the	citizen states toilet is barely flushing	Cleared // R Sawyer	8/26/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 14	10

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
63168	8/26/2020	Open	Jessica Davis	948 Arnold Ave.	662-820-8581		sewer issue in backyard	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						3 13	10
63170	8/26/2020	Closed	Cozetta Gray	1605 Pete Street	662-820-2672			Sewage smell in the house. Possible line clean out needed	Workers have been working on Reed Rd. There is now a sewage smell in the house.		Kyla Rice	670 Sewer	Jeff Appleton	No						3 11	37
63172	8/27/2020	Closed	Steve Harp	220 N California St.	6628222107			sewer issue	Cleared / R Sawyer	8/27/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 19B	28
63177	8/27/2020	Open	citizen	330 Nancy Street	662-632-9008		apartment complex	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63184	8/27/2020	Closed	Valeria Johnson	1133 Luster Street	972-689-2231			Please clean out sewer line	Dig-out on CITY / R Sawyer	8/27/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 7	16
63208	8/28/2020	Open	Chris	330 Deaton	662822-0887	owner of apartments wants someone in authority to call me		citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 5	14
63209	8/28/2020	Open	Chris	330 Nancy	662822-0887	owner of apartments wants someone in authority to call me		citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63213	8/28/2020	Closed	Sherry Haggard	1124 VFW Road	332-7229			sewage and water backing into her tub	Main down problem on property owner / R Sawyer	8/28/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						2 28A	53
63218	8/28/2020	Closed	citizen	640 Lotus	901-650-9832			citizen states toilet is barely flushing	Cleared / R Sawyer	8/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 15	10
63220	8/28/2020	Closed	Keidre Sutton	2238 Timber Cove	662-537-6061			citizen states toilet is barely flushing	Main down, problem on property owner / R Sawyer	8/28/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
63225	8/28/2020	Open	Charles Dorsey	680 W Mccorkle Circle	616.2040			leak in his yard			Bridgett Winters	670 Sewer	Jermaine Thornton	No						1 20	28
63231	8/31/2020	Closed	Arcelious Townsend	705 E Alexander	580.6227			sewage problems	Cleared // R Sawyer	9/2/2020	Bridgett Winters	670 Sewer	Jermaine Thornton	No						3 14	10
63246	9/1/2020	Closed	Malcolm Jackson	400 S Broadway	6628228342			sewer issue	Cleared // R Sawyer	9/1/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 4	7
63250	9/1/2020	Closed	Shelia Johnson	273 N Cotton Dr.	6623478129			Sewer issues; water is damaging floors	Dig-out on CITY // R Sawyer	9/1/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 9A	40
63256	9/1/2020	Closed	Tommy Sander( Street Dept)	502 Mill Rd.Public Works	6623785866			sewer issue	Cleared // R Sawyer	9/2/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 9A	40
63257	9/1/2020	Closed	Mcgray	484 Jo Anne	822.8653			sewage stopped up again, every 4 months	CITY side clear, problem on property owner // R Sawyer	9/2/2020	Bridgett Winters	670 Sewer		No						3 9B	40
63277	9/2/2020	Closed	Sandra Lang	2293 White Oak	379-3187			sewage stoppage	Cleared // R Sawyer	9/3/2020	Bridgett Winters			No						2 28A	53
63279	9/2/2020	Closed	Kenny Boston	1281 Belfast	347.6294	city employee		stoppage on city	Dig-out CITY // R Sawyer	9/3/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						1 32	21 & 22
63323	9/3/2020	Open	citizen	330 Nancy	662-632-9008			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63326	9/4/2020	Closed	R. Washington	1414 W Ollie Cir				sewer issue	Main down, problem on property owner // R	9/4/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 23	34
63332	9/4/2020	Closed	Sandra lane	2293 White Oak	379.3187			problem not resolved- you came out but sewage stopped up	Will use camera 9-8-20 // R Sawyer	9/4/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						2 28A	53
63335	9/4/2020	Closed	The Columbia PA	2434 South Paducha	662-820-3099			citizen states toilet is barely flushing	Main down, problem on property owner // R Sawyer	9/4/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 31B	23
63340	9/4/2020	Closed	Lena Berry	2106 White oak	662-347-5209		manhole	manhole overflowing, near her drive. Customer is having to drive through sewage	No issue, clear // R Sawyer	9/4/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
63341	9/4/2020	Closed	Charles Williams	619 West McCorkel Circle		sewage issue		citizen states toilet is barely flushing	Cleared // R Sawyer	9/4/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	28
63343	9/4/2020	Closed	Freddie Grayson	359 E Starling	580.2569			sewage stoppage	Cleared // R Sawyer	9/9/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						1 3C	55
63360	9/8/2020	Closed	Stanley Twilley	1735 Queen City Lane	616.1420			sewage stoppage	WATER LEAK, not sewer issue // R Sawyer	9/9/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						1 19B	28
63361	9/8/2020	Closed	R. Washington	168 Iris St.				sewer issue	No cleanout, MAIN DOWN // R Sawyer	9/9/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 11	37
63362	9/8/2020	Closed	Ruth Sharkey	1172 S Colorado	822.3019	city employees said dig out is required- sewage issue		sewage stoppage	Dig-out CITY, FLAGGED / R Sawyer	9/9/2020	Bridgett Winters	670 Sewer		No						3 22A	34
63364	9/8/2020	Closed	Michael Pruitt	116 Goldstein	6628227067		157 Oak Dr. & 116	Sewer backing up at both locations	cleared // R Sawyer	9/9/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 13	10
63371	9/8/2020	Closed	Beatrice Grace	507 North Cornell Apt	6625374099			Sewer issue partly on the city; pipe was	Main down, problem on property owner / R	9/9/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 31B	23
63372	9/8/2020	Closed	Latonya Lucas	2358 whippoorwill	347.4640			sewage stoppage	Cleared / R Sawyer	9/9/2020	Bridgett Winters	670 Sewer	Ronnie Washington	No						2 28A	53
63383	9/8/2020	Closed	Vanessa Daniels	720 S California St	6629311983			sewer issue	Cleared // R Sawyer		M. Kearney	670 Sewer	Jeff Appleton	No						2 21B	29
63393	9/9/2020	Closed	Dorothy Smith	611 Phelps St	6628203145			Sewer is stopped up	Cleared // R Sawyer	9/10/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 8	17
63394	9/9/2020	Closed	Sutton	2238 Timber Cove	537.6061			sewage stoppage	Cleared, problem is on property owner / R Sawyer	9/10/2020	Bridgett Winters	670 Sewer	Jeff Appleton	No						2 28A	53
63418	9/10/2020	Closed	Citizen	467 N Delesseps St.				sewer issue	cleared // R Sawyer	9/11/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3A	55
63424	9/10/2020	Closed	Vera Carter	1437 Causey Dr.	6625377859			sewer issue	Cleared // R Sawyer	9/11/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 21B	29
63430	9/11/2020	Closed	R. Washington	Freddies BBQ-- W Union St				sewer issue	Dig-out, CITY // R Sawyer	9/11/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3A	55
63432	9/11/2020	Closed	McGarrah Realty	1612 Les Lane	6623354592			sewer issue	Cleared // R Sawyer	9/11/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 21B	29
63436	9/11/2020	Open	Jamelba Fulton	2428 Hummingbird	662-207-2385		clean out at the front	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
63439	9/11/2020	Open	Mervin Boehs	244 West Reed Rd	662-822-0887		clean at the street	citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63448	9/14/2020	Open	citizen	285 Stockton Drive	662-931-4841			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
63456	9/14/2020	Closed	Sharzana Robinson	630 Deaton St	6624418377			sewer issue	Cleared, but on Property owner // R Sawyer	9/14/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 5	14
63473	9/15/2020	Open	citizen	1284 Kirk Circle	662-820-6477			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						3 25	11
63477	9/15/2020	Closed	Shelia Johnson	273 North Cotton Drive	662-347-8129			citizen states toilet is barely flushing	Dig-out, CITY // R Sawyer	9/16/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63480	9/15/2020	Closed	citizen	244 West Reed Rd	662-336-3407			citizen states toilet is barely flushing	Dig-out, CITY // R Sawyer	9/16/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63484	9/15/2020	Closed	Lonnie Johnson	232 Fava Dr.	6629311199			sewer backed up; plumber says its on the city	Cleared // R Sawyer	9/16/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 11	37

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
63512	9/16/2020	Closed	Darren Miller	1127 Luster	662-522-3905	sewer back-up		sewage backing up into the home.	Main down, problem on Property owner / R Sawyer		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 7	16
63520	9/16/2020	Closed	citizen	1120 Groome	662-347-4153			sewage backing up into the home.	Cleared / R Sawyer	9/17/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 22A	34
63521	9/16/2020	Closed	Darrell Moore	1127 Luster Street	662-458-2255			Neighbors may be experiencing sewage problems. He is unsure if he is having sewage issues as well	Main down, problem on Property owner / R Sawyer	9/17/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 7	16
63545	9/17/2020	Closed	Freddie Grayson	359 East Starling	662-580-2569			citizen states toilet is barely flushing	Cleared // R Sawyer	9/18/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 3C	55
63547	9/17/2020	Closed	Arceli Townsend	705 E Alexander	6625806227			sewer issue	Cleared // R Sawyer	9/18/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 14	10
63554	9/18/2020	Closed	Markita Thompson	837 Ashburn Rd	6628227478			Sewer is backed up and its on the city side;	Main down, problem on Property owner // R Sawyer	9/18/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 19A	28
63579	9/21/2020	Closed	Mozella Hawkins	1313 Luster	662-335-2567			citizen states toilet is barely flushing	City side clear, problem on property owner / R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 8	17
63580	9/21/2020	Closed	Willie Tyler	329 South Beauchamp	662-931-4097			citizen states toilet is barely flushing	Wrong complaint/ R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
63582	9/21/2020	Closed	Mervin Boehs	244 West Reed Rd				citizen states toilet is barely flushing	Dig-out.CITY / R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63586	9/21/2020	Closed	Blanc Williams	3554 Sherwood Drive	662-334-6523			citizen states toilet is barely flushing	Cleared // R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 29	25
63587	9/21/2020	Closed	Pepper	2359 Whiporwill St				sewer issue	Cleared / R Sawyer	9/22/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 28A	53
63588	9/21/2020	Closed	Teverrikk Perry	422 Hughes St. Apt 1	6625227314			sewer issue	Cleared // R Sawyer	9/22/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 6	13
63589	9/21/2020	Closed	citizen	1212 Ridge Avenue	662-334-6523			citizen states toilet is barely flushing	Cleared// R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63590	9/21/2020	Closed	Willie Tyler	320 South Beauchamp	6629314097			Sewer	Main down, problem on property owner // R Sawyer	9/22/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 30	56
63593	9/21/2020	Closed	Josphine Sawyer	983 Legion	662-931-3229			citizen states toilet is barely flushing	Cleared // R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 32B	20
63597	9/21/2020	Closed	Citizen	1408 E John St.				sewer issue	Cleared // R Sawyer	9/22/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 22A	34
63599	9/21/2020	Closed	Citizen	1408 E John Cove				sewer issue	Cleared // R Sawyer	9/22/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 22A	34
63600	9/22/2020	Open	Mervin Boehs	244 W. Reed Rd.				sewer issue			Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63611	9/22/2020	Closed	Linda Cook	2293 White Oak	662-379-3187			citizen states toilet is barely flushing	Dig-out CITY // R Sawyer	9/22/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 28A	53
63630	9/22/2020	Open	Eugene Ross	2430 Naples	662-37-1192			citizen states toilet is barely flushing	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	27
63632	9/23/2020	Closed	Adrain Moore	1178 Lewis St.	6623476666			sewer issue	System up // R Sawyer	9/24/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 9A	40
63633	9/23/2020	Closed	Mr. Knight	1516 South Delesseps	6623475133			Sewer issues; cannot flush the toilet	System up // R Sawyer	9/24/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 8	17
63634	9/23/2020	Closed	C F Shute	1164 Lewis	662-332-9949			citizen states toilet is barely flushing	System up // R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63649	9/23/2020	Closed	citizen	1008 Patton Drive	662-822-1940			citizen states toilet is barely flushing	System up // R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 32B	20
63651	9/23/2020	Closed	John Daniels	914 Susan Drive	662-378-2626			citizen states toilet is barely flushing	System up// R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 27	42
63652	9/23/2020	Closed	citizen	285 Stockson	662-931-4814			citizen states toilet is barely flushing	System up // R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 30	56
63656	9/23/2020	Closed	Ruth Sharkley	1172 South Colorado	662-822-3019			citizen states toilet is barely flushing	System up // R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 22A	34
63657	9/23/2020	Closed	Ricky Rhodes	1271 John Street	662-347-8220			citizen states toilet is barely flushing	System up // R Sawyer		Bridgette Adley	670 Sewer	Jeff Appleton	No						2 23	34
63658	9/23/2020	Closed	Micki Carter	1273 Groome Street	662-522-7902			citizen states toilet is barely flushing	System up // R Sawyer	9/24/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						2 23	34
63663	9/23/2020	Closed	Henry Miller	E Reed Rd & Raceway Rd.	6623787249			sewer issue/drainage@ Obannon School	System up // R Sawyer	9/24/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 29B	26
63686	9/24/2020	Closed	Marvin Fullerton	1297 John Street	662-522-3142			Sewage is backing up in both toilets	System up // R Sawyer	9/25/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 23	34
63689	9/24/2020	Closed	citizen	244 W Reed Rd				citizen states toilet is barely flushing	Dig-out / CITY // R Sawyer	9/25/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 9A	40
63695	9/24/2020	Closed	Angela Hood	429 East Clay Street	662-820-4731				Cleared // R Sawyer	9/25/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 6	13
63696	9/24/2020	Closed	R. Washington	1225 Hwy1 South				sewer issue	System up // R Sawyer	9/25/2020	M. Kearney	670 Sewer	Jeff Appleton	No						2 23	34
63697	9/24/2020	Closed	Philip Price	777 Carver Circle	6625222966			Sewage is backing up into home; water is	System up // R Sawyer	9/25/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 2	4
63699	9/24/2020	Closed	Willie Bee	438 S 9th St	6623472821			sewer issue	System up // R Sawyer	9/25/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 19B	28
63703	9/25/2020	Closed	Carla Beasley	537 South Percy St.	6623341512			Sewer needs to be rodded out	Cleared / R Sawyer	9/25/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 6	13
63709	9/25/2020	Closed	R. Washington	654 S California				sewer issue	Cleared / R Sawyer	9/25/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 20	28
63720	9/28/2020	Closed	R. Washington	461 Fava Dr.				sewer issue	Cleared / R Sawyer	9/29/2020	M. Kearney	670 Sewer	Jeff Appleton	No						3 11	37
63729	9/28/2020	Closed	R. Washington	1504 Hospital St				sewer issue	Main down, problem on property owner / R Sawyer	9/29/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 18	28
63735	9/28/2020	Closed	Mary Johnson	1507 Booker St.	6623945033			Sewer line is backed up on the city's side;	Cleared // R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						1 8	17
63737	9/28/2020	Closed	Arcelious Townsend	705 East Alexander St	6625806227			Sewer line needs to be blown out	Cleared // R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 14	10
63738	9/28/2020	Closed	Leah Rogers	1104 South Colorado	6625806382			Sewage line needs to be blown out	Cleared / R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 22A	34
63740	9/28/2020	Closed	Ray Roberts	3575 South Woodlawn	6628206172			Sewer is backed up; cleanout is next to the	Cleared / R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						2 29	25
63741	9/28/2020	Closed	Freddie Jones	1272 Groome St.	6628209049			Sewer is backed up	Cleared // R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						2 22A	34
63744	9/28/2020	Closed	Wanda Snyder	1451 Bradford Dr.	6623787067			Sewage is backing up into tub	Cleared // R Sawyer	9/29/2020	Lauren Gales	670 Sewer	Jeff Appleton	No						3 9B	40
63748	9/28/2020	Closed	Barbara Petty	422 Hughes Street Apt. 1	662-580-2622			Sewage problem	Sewage problems/ Backing up into apartment // Cleared // R Sawyer	9/29/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 6	13
63749	9/28/2020	Closed	Liza Bender	1250 Belfast Street	662-522-2080				Line cleared / R Sawyer	9/29/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						1 32	21
63750	9/28/2020	Open	R. Washington	1761 Holly Lane				sewer issue	Dig-out, CITY // R Sawyer	9/29/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 12	36
63751	9/28/2020	Open	R. Washington	1761				sewer issue	Cleared // R Sawyer	9/29/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 12	36
63752	9/28/2020	Closed	Anthony Williams	234 Terasa Drive	662-931-3473			Sewage problem	Line cleared // R Sawyer	9/29/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						1 10	38
63756	9/29/2020	Closed	Tiffany Craig	559 Southland Street	662-522-3861		A mop bucket is on top of the overflow of water	Sewage problems	Main down, no cleanout // R Sawyer	9/30/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						3 9B	40
63757	9/29/2020	Closed	Katherine McDuff	2445 Turin	662-394-0557			citizen states toilet is barely flushing	Main down, improper cleanout / R Sawyer	9/30/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						1 20	27
63758	9/29/2020	Closed	W. Scott	Hwy 1 South	662-822-1805		Pafford Ambulance	citizen states toilet is barely flushing	Cleared / R Sawyer	9/30/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 16	54
63762	9/29/2020	Closed	Imogene Green	256 Mill Road	662-580-6586			Sewage problems	Cleared / R Sawyer	9/30/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						1 9A	40
63766	9/29/2020	Closed	Minnie McCarter	726 South Delesseps	662-931-4717			Sewage problems	Sewage line needs to be cleaned out. // Cleared / R Sawyer	9/30/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						2 7	16
63770	9/29/2020	Closed	R. King	Hampgreen St Rose Hill Church				sewer issue	Cleared / R Sawyer	9/30/2020	M. Kearney	670 Sewer	Jeff Appleton	No						1 3A	55
63781	9/30/2020	Closed	Cotina Larvenia	237 Fava	662-347-4547			citizen states toilet is barely flushing	Cleared / R Sawyer	10/1/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						3 11	37

EIGHTEENTH QUARTERLY REPORT  
OCTOBER 23, 2020  
PARTIAL CONSENT DECREE  
U.S. DISTRICT COURT CIVIL ACTION 4:16-CV-00018

Work Order #	Work Date	Main Status	Requestor Name	Address	Phone Number	Event Name	Location	Customer Description	Work Description	Date Delivered	Received By	Department	Assigned To	SSO	Duration (hours) if	Volume (gallons)	Waters of U.S.	Cause	Group	Mini-system	Pump Station
63784	9/30/2020	Open	Thomas Donovan w/	South Broad & Main	601-506-8241			sewer issue, needing to speak with someone in	sewer maintenance		Bridgette Adley	670 Sewer	Jeff Appleton	No						34	7
63785	9/30/2020	Closed	Tiffany Smith	559 Southland	662-379-0290			citizen states toilet is barely flushing	Main down, no cleanout // R Sawyer	10/1/2020	Bridgette Adley	670 Sewer	Jeff Appleton	No						39B	40
63789	9/30/2020		Nikeka Nelson	522 Kentucky Street	662-379-1009			Sewage problems	Sewage line needs to be cleaned out.		Kyla Rice	670 Sewer	Jeff Appleton	No						119B	28
63790	9/30/2020	Closed	Nikeka Nelson	522 Kentucky Street	662-379-1009			Sewage problems	Cleared CITY side, property owner still has problem on their side/ R Sawyer	10/1/2020	Kyla Rice	670 Sewer	Jeff Appleton	No						119B	28

**WASTEWATER BYPASS REPORT**  
**TO THE MISSISSIPPI OFFICE OF POLLUTION CONTROL**

- I. PERMITTEE NAME: **CITY OF GREENVILLE, MS**
- II. PERMIT NUMBER: **MS0020184**
- III. BYPASS SOURCE (I.E. MANHOLE PUMP STATION, ETC.): Force Main
- IV. SOURCE LOCATION (I.E. STREET, ETC.): Highland Plantation Road
- V. DATE/TIME BYPASS BEGAN: 7/01/2020- 2:00 p.m.
- VI. DATE/TIME BYPASS ENDED: 7/2/2020- 10:00 a.m.
- VII. VOLUME OF WASTERWATER BYPASSED (ESTIMATE IF NECESSARY) 10,000 gal
- VIII. STATE WATERS EFFECTED (I.E. RIVER, STREAM, LAKE, ETC,) **NONE**
- IX. CAUSE OF BYPASS: Aged pipe/normal wear
- X. TEMPORARY CORRECTIVE ACTIONS TAKEN: Point Repair
- XI. PERMANENT CORRECTIVE ACTIONS: Replace the section of pipe
- XII. NUMBER OF BYPASSES AT THIS LOCATION IN THE PAST 12 MONTHS: 03
- XIII. WHAT ACTIONS WERE TAKEN TO PREVENT OR MINIMIZE ADVERSE ENVIROMENTAL IMPACT? Barricaded the area off.
- XIV. IF BYPASS CAUSED DUE TO INFLOW OR RAINFALL, HOW MANY INCHES OF RAIN FELL IN THE AREA? 0"

SIGNATURE:

*Ronnie Washington*

TITLE: Street Utility Director

ADDRESS: 340 MAIN STREET  
GREENVILLE, MS 38701

DATE: July 7, 2020

## WASTEWATER BYPASS REPORT

### TO THE MISSISSIPPI OFFICE OF POLLUTION CONTROL

- I. PERMITTEE NAME: CITY OF GREENVILLE, MISSISSIPPI
- II. PERMIT NUMBER: MS0020184
- III. BYPASS SOURCE (I.E. MANHOLE, PUMP STATION, ETC.): Force Main
- IV. SOURCE LOCATION (I.E. STREET, ETC.): 1148 Highland Plantation Road
- V. DATE/TIME BYPASS BEGAN: September 18, 2019 @ 4:00 pm
- VI. DATE/TIME BYPASS ENDED: Bypass has been contained.
- VII. VOLUME OF WASTEWATER BYPASSED (ESTIMATE IF NECESSARY) Approximately 2500 gals
- VIII. STATE WATERS EFFECTED (I.E. RIVER, STREAM, LAKE, ETC. NONE: n/a
- IX. CAUSE OF BYPASS: Break in Force main
- X. TEMPORARY CORRECTIVE ACTIONS TAKEN: Bypass has been contained.
- XI. PERMANENT CORRECTIVE ACTIONS: Contractor starting today.
- XII. NUMBER OF BYPASSES AT THIS LOCATION IN THE PAST 12 MONTHS: 5
- XIII. WHAT ACTIONS WERE TAKEN TO PREVENT OR MINIMIZE ADVERSE ENVIRONMENTAL  
IMPACT?
- XIV. IF BYPASS CAUSED DUE TO INFLOW OF RAINFALL, HOW MANY INCHES OF RAIN FELL IN THE  
AREA?

SIGNATURE: Ronnie Washington  
TITLE: Street Utility Director  
ADDRESS: 340 MAIN STREET  
GREENVILLE, MISSISSIPPI 38701  
Date: 10/3/19

**WASTEWATER BYPASS REPORT**  
**TO THE MISSISSIPPI OFFICE OF POLLUTION CONTROL**

- I. PERMITTEE NAME: **CITY OF GREENVILLE, MS**
- II. PERMIT NUMBER: **MS0020184**
- III. BYPASS SOURCE (I.E. MANHOLE PUMP STATION, ETC.): Bypass pump
- IV. SOURCE LOCATION (I.E. STREET, ETC.): 1840 Palmyra
- V. DATE/TIME BYPASS BEGAN: 9/08/2020- 8:00 a.m.
- VI. DATE/TIME BYPASS ENDED: 9/08/2020 -9:45 a.m.
- VII. VOLUME OF WASTERWATER BYPASSED (ESTIMATE IF NECESSARY) 200 gal
- VIII. STATE WATERS EFFECTED (I.E. RIVER, STREAM, LAKE, ETC,) **NONE**
- IX. CAUSE OF BYPASS: Vehicle ran over the hose causing damage
- X. TEMPORARY CORRECTIVE ACTIONS TAKEN: Repaired the hose
- XI. PERMANENT CORRECTIVE ACTIONS: Repair the failure
- XII. NUMBER OF BYPASSES AT THIS LOCATION IN THE PAST 12 MONTHS: 01
- XIII. WHAT ACTIONS WERE TAKEN TO PREVENT OR MINIMIZE ADVERSE ENVIROMENTAL IMPACT? Clean area and put lime
- XIV. IF BYPASS CAUSED DUE TO INFLOW OR RAINFALL, HOW MANY INCHES OF RAIN FELL IN THE AREA? 0"

**SIGNATURE:**

*Ronnie Washington*

**TITLE:** Street Utility Director

**ADDRESS:** 340 MAIN STREET  
GREENVILLE, MS 38701

**DATE:** September 7 2020